

# CLMS-21-1061-22-14637-15-c

The accreditation by the COFRAC Laboratory Section attests to the technical competence of the laboratory only for the tests covered by the accreditation. This test report attests only the characteristics of the object submitted for testing but does not prejudice the characteristics of similar products. So, it does not constitute a product certification in the sense of the Consumer Code.

If this report is being issued via an electronic channel and/or on physical electronic media, only the paper version of the report signed by CSTB shall be deemed authentic in case of litigation. This report in paper form is kept at CSTB for a minimum period of 10 years. The reproduction of this test report is only authorised in its integral form.

In accordance with the General Terms And Conditions On The Provision Of Services, the information relating to the description of the products and the data identified by (data provided by manufacturer) are provided by the applicant and under their full responsibility.

**Request by**

Tecno-Ventil SPA  
Via Degli Imprenditori  
4 26016 Spino d'Adda (CR)  
Italy

## Fan Coil Unit 2 Pipes Variable Speed

**Date of the test report : 31/01/2023**

## Laboratory

### CSTB

290 route des Lucioles  
06904 Sophia Antipolis

## Client

### Tecno-Ventil SPA

Via Degli Imprenditori  
4 26016 Spino d'Adda (CR)  
Italy

## Licensee

### Tecno-Ventil SPA

Via Degli Imprenditori  
4 26016 Spino d'Adda (CR)  
Italy

## Manufacturer

### Tecno-Ventil SPA

Via Degli Imprenditori  
4 26016 Spino d'Adda (CR)  
Italy

## 1. Test conditions

|                        |   |
|------------------------|---|
| <b>Specifications</b>  | EN15500-1:2017<br>eu.bac CERT PART 1 - General rules - Version 15 - February 2016<br>eu.bac CERT PART 2-1 – Specific rules - IZC version 5.0 – April 2019 |
| <b>Application</b>     | Fan Coil Unit 2 Pipes Variable Speed  |
| <b>Test Mode</b>       | Cooling   |
| <b>Operating modes</b> | Comfort, Economic   |

## 2. Controller

|  |               |
|--|---------------|
| <b>Product identification</b>              | MRC-CTRL-IO   |
| <b>Software version</b>                    | Not Specified |
| <b>Production date</b>                     | 2021          |
| <b>Serial number</b>                       | Not Specified |
| <b>Manufacturer product identification</b> | MRC           |
| <b>Laboratory identification</b>           | 21-06786      |

## 3. Test components

### 3.1. Room unit

|  |               |
|--|---------------|
| <b>Product identification</b>              | MRC-T3        |
| <b>Production date</b>                     | 2021          |
| <b>Serial number</b>                       | Not Specified |
| <b>Manufacturer product identification</b> | MRC-T3        |
| <b>Laboratory identification</b>           | 21-06786      |

### 3.2. Valve

|                                  |                    |
|----------------------------------|--------------------|
| <b>Product identification</b>    | TA-COMPACT-P (IMI) |
| <b>Serial number</b>             | Not Specified      |
| <b>Laboratory identification</b> | 21-07859           |

|                       |  |
|-----------------------|--|
| <b>Characteristic</b> | Linear (data provided by manufacturer) |
| <b>Type</b>           | Globe (data provided by manufacturer)  |
| <b>Stroke [mm]</b>    | 3.8                                    |

### 3.3. Valve Actuator

|                                  |   |
|----------------------------------|---|
| <b>Product identification</b>    | TA Compact                              |
| <b>Serial number</b>             | Not Specified                           |
| <b>Laboratory identification</b> | 26063899                                |
| <b>Running time [s]</b>          | 90                                      |
| <b>Type</b>                      | Thermal (data provided by manufacturer) |

### 3.4. Temperature sensor


|                                |                                   |
|--------------------------------|-----------------------------------|
| <b>Sensor type</b>             | Tecno-Ventil_NTC_10K_6            |
| <b>Time constant (minutes)</b> | 6 (data provided by manufacturer) |

#### Temperatures resistances table

|      |        |
|------|--------|
| 0°C  | 27218Ω |
| 1°C  | 26076Ω |
| 2°C  | 24987Ω |
| 3°C  | 23950Ω |
| 4°C  | 22962Ω |
| 5°C  | 22021Ω |
| 6°C  | 21123Ω |
| 7°C  | 20266Ω |
| 8°C  | 19449Ω |
| 9°C  | 18669Ω |
| 10°C | 17925Ω |
| 11°C | 17213Ω |
| 12°C | 16534Ω |
| 13°C | 15885Ω |
| 14°C | 15265Ω |
| 15°C | 14673Ω |

|      |        |
|------|--------|
| 16°C | 14107Ω |
| 17°C | 13566Ω |
| 18°C | 13048Ω |
| 19°C | 12554Ω |
| 20°C | 12080Ω |
| 21°C | 11628Ω |
| 22°C | 11194Ω |
| 23°C | 10779Ω |
| 24°C | 10381Ω |
| 25°C | 10000Ω |
| 26°C | 9634Ω  |
| 27°C | 9283Ω  |
| 28°C | 8947Ω  |
| 29°C | 8624Ω  |
| 30°C | 8314Ω  |

### Temperature Sensor Calibration



## 4. Test schedule

|               |  |
|---------------|--|
| Operator      | Adam TCHA-KONDOR (Operator)              |
| Supervisor    | Jean-Charles CORBIN (Laboratory Manager) |
| Begin of test | 28/11/2022 11:18:13                      |
| End of test   | 28/11/2022 16:18:19                      |

## 5. Results

The test results presented in this report relate only to item(s) tested.

### 5.1. Comfort mode

Test periods, time range and extreme temperatures

#### Comfort mode 1

| Period | Internal gain | Time range [h] | T min [°C] | T max [°C] |
|--------|---------------|----------------|------------|------------|
| 2      | 0%            | 6:45 - 9:00    | 23.61      | 24.14      |
| 4      | 30%           | 9:45 - 12:00   | 23.74      | 24.19      |
| 6      | 60%           | 12:45 - 15:00  | 23.91      | 24.05      |

#### Comfort mode 2

| Period | Internal gain | Time range [h] | T min [°C] | T max [°C] |
|--------|---------------|----------------|------------|------------|
| 2      | 0%            | 6:45 - 9:00    | 23.61      | 24.14      |
| 4      | 30%           | 9:45 - 12:00   | 23.73      | 24.21      |
| 6      | 60%           | 12:45 - 15:00  | 23.92      | 24.06      |

#### Temperature control accuracy

$$CV = \frac{\max_{period2,4,6}(T_{in,max}) - \min_{period2,4,6}(T_{in,min})}{2}$$

$$CSD = \frac{\max_{period2,4,6}(T_{in,max}) + \min_{period2,4,6}(T_{in,min})}{2} - T_{setpoint}$$

**Comfort mode 1**

|                              |            |
|------------------------------|------------|
| Control accuracy :           | CA = 0.3   |
| Control setpoint deviation : | CSD = -0.1 |
| Control variation :          | CV = 0.3   |

**Comfort mode 2**

|                              |            |
|------------------------------|------------|
| Control accuracy :           | CA = 0.3   |
| Control setpoint deviation : | CSD = -0.1 |
| Control variation :          | CV = 0.3   |

Simulation graphics are available in the appendix

**5.2. Economic mode**

The set point temperature for economic mode is 26.00°C

|  |   |
|--|---|
| First time the setpoint tolerance is reached | Measured mean value of the temperature [°C] |
| 0:09   | 25.94                                       |

Simulation graphics are available in the appendix




**6. Results summary**




| Test type     | Results      | Conditions               | Approval |
|---------------|--------------|--------------------------|----------|
| Comfort Mode  | CA = 0.30°C  | CA < 1.40°C              | yes      |
| Economic Mode | TM = 25.94°C | Teco - 1 < TM < Teco + 1 | yes      |



To declare, or not, the compliance with the specifications, the standard uncertainty of the laboratory was added to the test results.




## Appendix


### Comfort Mode : curves of the simulation results







**Economic Mode : curves of the simulation results**



---

**Laboratory equipments****Resistance box**

|   |                                       |
|---|---------------------------------------|
| <b>Name</b>                               | 13 0728                               |
| <b>Laboratory identification</b>          | 13 0728                               |
| <b>Slope [<math>\Omega/\Omega</math>]</b> | 1                                     |
| <b>Y-intercept [<math>\Omega</math>]</b>  | -1.6                                  |
| <b>Calibration report name</b>            | CEC F0/18708 (Valid until 15/12/2022) |

**Stroke measurement sensor**

|                                  |  |
|----------------------------------|--|
| <b>Name</b>                      | 13 0729                                |
| <b>Laboratory identification</b> | CSTB                                   |
| <b>Slope [mm/V]</b>              | 1.93513                                |
| <b>Y-intercept [mm]</b>          | -0.01254                               |
| <b>Calibration report name</b>   | DT 21 0046 (validity until 10/02/2023) |

**Fan**

|                 |           |
|-----------------|-----------|
| <b>Name</b>     | Fan 0-10V |
| <b>Umin [V]</b> | 0         |
| <b>Umax [V]</b> | 10        |

**Software**

ETT IZC Version 6.0.1.1

License number : 6C308FA2-401B-4AB3-86B2-F3089B7DEFC3

--- END OF THE REPORT ---